



Republic of the Philippines
QUEZON CITY GOVERNMENT
BAC- Goods and Services
2nd Floor, Procurement Department,
Finance Building, Quezon City Hall Compound



REQUEST FOR QUOTATION
SMALL VALUE PROCUREMENT
(SECTION 53.9)

Date : August 03, 2021
PR No. : GF-21-03-00176

Name of Company : _____
Address : _____
Contact No. : _____
Project Title : **SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF AIR DISINFECTION PURIFIER**
Approved budget of the Contract : **Php 463,500.00**
End-User /
Implementing Office : **REGIONAL TRIAL COURT**

Please quote your best offer for the item/s described below, subject to the Terms and Conditions provided. Submit your quotation duly signed by you or your duly authorized representative not later than AUGUST 06, 2021, 10:00AM Philippine Standard Time, together with the following documents of your company:

- 1 PhilGEPS certificate (not expired on the time of opening of quotations);
- 2 Business Registration (DTI/SEC)
- 3 Mayor's/Business Permit (2021);
- 4 Tax Clearance; and
- 5 Omnibus Sworn Statement prescribed by **QC BAC – Goods and Services**
- 6 Income/Business Tax Return (for FY 2020) (For ABC P500,000.00 above)
- 7 If applicable, the JVA in case the joint venture is already in existence, or duly notarized statements from all the potential joint venture partners stating that they will enter into and abide by the provisions of the JVA in the instance that the bid is successful.


in a **SEALED LONG BROWN ENVELOPE** shall:

- 1 Contain the Project Name and PR Number of the contract to be bid in capital letters;
- 2 Bear the name and address of the Bidder in capital letters;
- 3 Be addressed to the Procuring Entity's BAC.

Project Title : **SUPPLY, INSTALLATION, TESTING AND COMMISSIONING**
OF AIR DISINFECTION PURIFIER

Quezon City Local Government
BIDS AND AWARDS COMMITTEE
2/F Procurement Department, Finance Building
Quezon City Hall Compound

For any clarification you may contact us at 89884242 loc. 8506/8709.


LATTY. DOMINIC B. GARCIA
Officer-in-Charge / Head, BAC Secretariat

TERMS AND CONDITIONS

- 1. Bidders shall provide correct and accurate information required in this form in black ink only.
- 2. Price quotation/s must be valid for a period of thirty (30) calendar days from the date of submission.
- 3. Price quotation/s, to be denominated in Philippine Peso shall include all taxes, duties and/or levies payable.
- 4. Quotation exceeding the Approved Budget for the Contract (ABC) shall be rejected.
- 5. Award of contract shall be made to the lowest quotation (for goods) or the highest rated offer (for consulting services) which complies with the minimum technical specifications and other terms and conditions stated herein.
- 6. Any interlineations, erasures or overwriting shall be valid only if they are signed or initiated by you or any of your duly authorized representative/s.
- 7. The City General Services Department (CGSD) shall have the right to inspect the goods.
- 8. Non-submission of eligibility documents shall mean disqualification of Quotation.
- 9. Liquidated damages equivalent to one tenth (1/10) of one percent (1%) of the value of the goods not delivered within the prescribed delivery period shall be imposed per day of delay. CGSD shall rescind the contract once the cumulative amount of liquidated damages reaches ten percent (10%) of the amount of the contract, without prejudice to other courses of action and remedies open to it.
- 10. Failure to follow these instructions will disqualify your entire quotation.

After having carefully read and accepted the Terms and Conditions, I/We submit our quotation/s as follows:

ITEM NO.	ITEM & DESCRIPTION	UNIT OF ISSUE	QTY.	UNIT PRICE	ITEM TOTAL
1	SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF AIR DISINFECTION PURIFIER Specifications: Circulating Air Volume: 60m3/h @Opa. Disinfection bacteria-killing technology: Germanic slow-released molecules + wholly – ; Disinfection Efficiency: 99%; Killing rate of virus (influenza A and B virus): 99%; Killing rate of MERS Coronavirus: 96%; Noise: 45dB(A) @ 1m; Way of air flow-in and flow out: Breathe in from bottom and return from front; Rated voltage of adaptor: 220V 50/60Hz; Max operation current: 1.2A(24V DV); Output voltage of adaptor (connecting to product) 24V DC; Rated power: 30W Standby power: 3W; Range of working temperature: 20°C – 45°C; Range of working humidity: Relative humidity from 5% to 95%; Maintenance requirement: Top maintenance of filter; Maintenance Period: Germanic slow released molecular fitter: 90 days (normal); Maintenance period: UV photo catalyst assembly; 360 days; External Dimension (width x height x thickness): 300*150*66mm; Net weight: 1.5 kg.	unit	3		
Total Quoted Amount					

Amount in Words: _____

Other Requirement/s:
❖ Statement of Warranty – minimum of one (1) year

Delivery Period : Thirty (30) Calendar Days
Warranty : _____

Signature over printed name

Office Telephone No./Fax/Mobile No.

Date

E-mail Address