



Republika ng Pilipinas
Lungsod Quezon
BIDS AND AWARDS COMMITTEE –
GOODS AND SERVICES

Second Floor, Civic Center Building F, Quezon City Hall Complex, Elliptical Road, Quezon City
 Tel. No. 8988-42-42 local 8709/8712



BID BULLETIN NO. 29-2022
Series of 2022

Notice is hereby given to all concerned bidders for the following Project
 scheduled for Public Bidding on **19 September 2022**, viz:

Project Title: PROCUREMENT OF FIRE HOSE Project No.: OCM(POPS)-22-SOP-995									
FROM	TO								
<p>Under Section VI. Schedule of Requirements and Section VII. Technical Specifications</p> <table border="1"> <tr> <td align="center">1</td> <td>1 ½ 50ft. Anodized aluminum coupling inter twine polyester yarns, 400psi service test pressure. FM or UL or NFPA International Standard</td> </tr> <tr> <td align="center">2</td> <td>2 ½ 50ft. Anodized aluminum coupling inter twine polyester yarns, 400psi service test pressure. FM or UL or NFPA International Standard</td> </tr> </table> <p>D. Fire Hose Coupling or Adapter 1. A pair of swivel type male and female aluminum coupling complete with gasket and expansion ring shall be attached to the end section of the hose.</p> <ul style="list-style-type: none"> Delivery Period: Thirty (30) Calendar Days <p>Under Bid Data Sheet ITB Clause 21.2 and Checklist of Technical and Financial Documents III</p> <ul style="list-style-type: none"> Statement of Warranty – minimum of One (1) Year 	1	1 ½ 50ft. Anodized aluminum coupling inter twine polyester yarns, 400psi service test pressure. FM or UL or NFPA International Standard	2	2 ½ 50ft. Anodized aluminum coupling inter twine polyester yarns, 400psi service test pressure. FM or UL or NFPA International Standard	<p>Under Section VI. Schedule of Requirements and Section VII. Technical Specifications</p> <table border="1"> <tr> <td align="center">1</td> <td>1 ½ 50ft. Anodized aluminum coupling inter twine polyester yarns, 400psi service test pressure. NFPA 1961 Certifications for the hoses or its equivalent</td> </tr> <tr> <td align="center">2</td> <td>2 ½ 50ft. Anodized aluminum coupling inter twine polyester yarns, 400psi service test pressure. NFPA 1961 Certifications for the hoses or its equivalent</td> </tr> </table> <p>D. Fire Hose Coupling or Adapter 1. A pair of swivel type male and female aluminum coupling complete with gasket and expansion ring shall be attached to the end section of the hose. It is the normal design for NH threaded fire hoses which has a male NH thread on one end and a female NH end with a swivel coupling on the other end.</p> <ul style="list-style-type: none"> Delivery Period: One Hundred Twenty (120) Calendar Days <p>Under Bid Data Sheet ITB Clause 21.2 and Checklist of Technical and Financial Documents III</p> <ul style="list-style-type: none"> Statement of Warranty – minimum of One (1) Year NFPA 1961 Certifications or its equivalent 	1	1 ½ 50ft. Anodized aluminum coupling inter twine polyester yarns, 400psi service test pressure. NFPA 1961 Certifications for the hoses or its equivalent	2	2 ½ 50ft. Anodized aluminum coupling inter twine polyester yarns, 400psi service test pressure. NFPA 1961 Certifications for the hoses or its equivalent
1	1 ½ 50ft. Anodized aluminum coupling inter twine polyester yarns, 400psi service test pressure. FM or UL or NFPA International Standard								
2	2 ½ 50ft. Anodized aluminum coupling inter twine polyester yarns, 400psi service test pressure. FM or UL or NFPA International Standard								
1	1 ½ 50ft. Anodized aluminum coupling inter twine polyester yarns, 400psi service test pressure. NFPA 1961 Certifications for the hoses or its equivalent								
2	2 ½ 50ft. Anodized aluminum coupling inter twine polyester yarns, 400psi service test pressure. NFPA 1961 Certifications for the hoses or its equivalent								

Please be guided accordingly.

By: **BIDS AND AWARDS COMMITTEE - GOODS AND SERVICES**

MS. MA. MARGARITA T. SANTOS
 Chairperson

Handwritten initials/signature