



Republika ng Pilipinas
Lungsod Quezon
BIDS AND AWARDS COMMITTEE –
GOODS AND SERVICES



Second Floor, Civic Center Building F, Quezon City Hall Complex, Elliptical Road, Quezon City
Tel. No. 8988-42-42 local 8709/8712

BID BULLETIN NO. 40-2022
Series of 2022

Notice is hereby given to all concerned bidders for the following Projects
scheduled for Public Bidding on **November 23, 2022**, viz:

Project Title: PROCUREMENT OF PRINTER AND OTHERS Project No.: DBO-22-OE-1272	
FROM	TO
<ul style="list-style-type: none">•Section VI. Schedule of Requirements, and•Section VII. Technical Specifications <p>VOLTAGE STABILIZER</p> <p>Capacity: 2KVA/1600W Servo Motor; Input Voltage: 220VAC or 230VAC single phase; Input Voltage Range: 130-270VAC; Input Frequency: 50Hz/60Hz; Output Voltage: 220VAC or 230VAC single phase +/- 1-3% Output Frequency: 50Hz/60Hz; 3s Delay Function; Input Full Protection: Over-voltage, Under-voltage, Over-temp, Over-current protection; Response Time: < 1 sec (against 10% input voltage variation); Input Full Protection: Over-voltage, Under-voltage, Over-temp, Over-current protection, must be sufficient to the equipment</p>	<ul style="list-style-type: none">•Section VI. Schedule of Requirements, and•Section VII. Technical Specifications <p>VOLTAGE STABILIZER (UNINTERRUPTIBLE POWER SUPPLY)</p> <p>Capacity: 2KVA/1600W Servo Motor; Input Voltage: 220VAC or 230VAC single phase; Input Voltage Range: 130-270VAC; Input Frequency: 50Hz/60Hz; Output Voltage: 220VAC or 230VAC single phase +/- 1-3% Output Frequency: 50Hz/60Hz; 3s Delay Function; Input Full Protection: Over-voltage, Under-voltage, Over-temp, Over-current protection; Response Time: < 1 sec (against 10% input voltage variation); Input Full Protection: Over-voltage, Under-voltage, Over-temp, Over-current protection, must be sufficient to the equipment</p>

By: **BIDS AND AWARDS COMMITTEE – GOODS AND SERVICES**


MS. MA. MARGARITA T. SANTOS
Chairperson